



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
TTY: Contact Through Relay

Scott Walker, Governor  
Dave Ross, Secretary

July 22, 2011

SIOUX CHIEF MFG, CO. INC.  
DON KUSMEC  
2411 SOUTH PECULIAR RD  
PECULIAR MO 64078

Re: Description: FITTINGS, COPPER, CPVC OR PEX  
Manufacturer: SIOUX CHIEF MFG, CO. INC.  
Product Name: FIT QUICK  
Model Number(s): SEE ATTACHMENT A  
Product File No: 20110219

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 (5) based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of July 2016.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may be installed for the following use(s)
  - a. Water distribution piping . . . . aboveground
  - b. Water distribution piping . . . . belowground
  - c. Water service
- This product may be used to join together copper that complies with ASTM B88, CPVC that complies with ASTM D2846 or CSA B137.6 and PEX that complies with ASTM F876, ASTM F877 or ASTM F1281.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

A handwritten signature in black ink that reads 'Jerry Thompson'. The signature is written in a cursive style and is enclosed within a hand-drawn oval.

Jerry Thompson  
Plumbing Product Reviewer  
Phone: 608-266-6742  
Fax: 608-267-9566  
E-mail: jerry.thompson@wi.gov